

A1

306030 Redacted

NOTES  
 CO-ORDINATES ARE IN TERMS OF NZ MAP GRID  
 NEW WATERMAIN IS 180mm OD HDPE  
 CLASS-PN16  
 TYPE-PE100SDR11  
 ALL VALVE FITTINGS AVK  
 ALL FITTINGS MANUFACTURED-TYCO  
 INSTALL DATES- 10/2005 TO 11/2005

PRESSURE RELIEF VALVE  
 N: 6391781.56  
 E: 2790448.61

150NB PIPE SPOOL

VALVE  
 N: 6391780.55  
 E: 2790448.29

A40-T INTERSECTION  
 N: 6391781.65  
 E: 2790450.46

PUMP STATION BUILDING

200NB PRESSURE RELIEF  
 VALVE DISCHARGE PIPE

BUBBLE UP SUMP  
 (OVERFLOW FROM PRESSURE  
 RELIEF VALVE)

A41-T INTERSECTION  
 N: 6391779.57  
 E: 2790447.79

GRUNFOS CR90 PUMP  
 N: 6391780.64  
 E: 2790448.17

TAURANGA DISTRICT COUNCIL  
 "AS BUILT PLANS"  
 Checked s 7(2)(a) - Privacy  
 Approved  
 Date 7.09.06

11263

S 11264

25035 GIS  
 RECORDED

PRELIMINARY DRAFT

	Name	Date
SURVEYED		
DESIGNED	s 7(2)(a)	
DRAWN		
CHECKED		
APPROVED		

Scale Stamp	PRELIMINARY DRAFT		
Date Stamp	21/12/05		
SCALES (A1) 1:20	Job No.	Sheet No.	Rev.
	303523	DIA 1	