

A1-FIRE HYDRANT
 N: 6392428.45
 E: 2790159.31

A27-EHD CAP
 N: 6392428.99
 E: 2790159.79

180 OD HDPE

180 OD HDPE

JOHNLIN

WATERMAIN LEAVES VEHICLE

TAURANGA DISTRICT COUNCIL
 "AS BUILT PLANS"
 Checked s 7(2)(a) - Privacy
 Approved
 Date 1-09-06

11263
 11264
 GIS
 RECORDED

NOTES
 CO-ORDINATES ARE IN TERMS OF NZ MAP GRID
 NEW WATERMAIN IS 180mm OD HDPE
 CLASS-PN16
 TYPE-PE100SDR11
 ALL VALVE FITTINGS AVK
 ALL FITTINGS MANUFACTURED-TYCO
 INSTALL DATES- 10/2005 TO 11/2005

25034 PRELIMINARY DRAFT



	Name	Date
SURVEYED	JM	
DESIGNED		
DRAWN		
CHECKED		

MAUAO
 FIRE FIGHTING WATER MAIN AS BUILT
 TAURANGA CITY COUNCIL

Status Stamp	PRELIMINARY DRAFT
Date Stamp	16/01/06
Scale	1:500
Job No.	306034
Sheet No.	5
Rev.	